

Technology Solutions to Upgrading Transmission Equipment Capacity

Enda Feeley, EirGrid



Developing the Grid - Grid25




A Strategy for the
Development of Ireland's
Electricity Grid for
a Sustainable and
Competitive Future

GRID25

2,300 km Upgrades

1,150 km New Build

€4 billion



Technology Solutions

- Overhead Lines
 - Conversion of AC circuits to DC operation
 - Voltage uprate of existing transmission circuits
 - Dynamic line monitoring
 - High Temperature Low Sag (HTLS) conductors
- Substations
 - Gas Insulated Switchgear
 - Compact Switchgear
 - HTLS busbar conductors
 - FACTS Devices
 - Temperature monitoring



HTLS Requirements & Criteria

•Upgrading Requirements

Voltage	Existing Conductor Type	Existing Rating (A/MVA)	Desired Rating (A/MVA)	Increase
110 kV	200 mm ² ACSR	107	187	75%
110 kV	300 mm ² ACSR	137	187	36%
220 kV	430 mm ² ACSR	286	605	50%
220 kV	600 mm ² ACSR	431	742	50%


HTLS Conductors – Technical

5 Different Types of HTLS Conductors Considered :-



- ACSS : Aluminium Conductor, Steel Supported
- Invar: XTACIR/ZTACIR (Iron-Nickel alloy core)
- ACCR : Aluminium Conductor Composite Reinforced
- ACCC : Aluminium Conductor Composite Core
- GAP : G(Z)TACSR



Sag / Tension Example



GAP Conductor Details



GZTACSR Cross-Section

- Unique Construction
- Steel core carries the load of the conductor (including aluminium)
- Combination of GAP construction and ZTAL outer wires offers excellent sag and current carrying characteristics
- Bespoke conductor designs available

GAP Vs ACSR

- 430sq.mm Conductors
- 1600A DC Current
- 160°C DC
- GAP sags 1.1m less over 40m span



Installation Process

- Non – standard installation process (2 stages)
- Stage 1. Aluminium wires are de-stranded, Steel core exposed, compressed and left to settle
- Stage 2. Final sag adjusted and aluminium wires re-stranded
- Similar to OPPC installation
- 10 – 15% increase in stringing duration



Benefits 1/4

- Increased Rating:

Voltage	Existing Conductor Type	Existing Rating (A/MVA)	GAP Uprate (A/MVA)	Increase (Summer)
110 kV	200 mm ² ACSR	562 / 107	981 / 187	75%
110 kV	300 mm ² ACSR	719 / 137	1200 / 228	65%
220 kV	430 mm ² ACSR	751 / 286	1500 / 570	100%
220 kV	600 mm ² ACSR	1131 / 431	2025 / 771	80%



Benefits 2/4

- Reduced Cost: (Note GAP costs are estimates and are subject to change depending on existing asset condition)

Voltage	Uprate Type	Standard Charge (per km)	GAP Uprate (per km)	Savings (per km)	
				€	%
110 kV	200 mm ² to 430 mm ² ACSR	€259,000	€110,000	€150,000	≈60%
110 kV	300 mm ² to 430 mm ² ACSR	€259,000	€110,000	€150,000	≈60%
220 kV	430 mm ² ACSR plus 50% extra	€172,000	€80,000	€82,000	≈50%
220 kV	600 mm ² ACSR plus 50% extra	€700,000 (estimated)	€100,000	€600,000	≈85%



Benefits 3/4

- Electric and Magnetic Fields
 - Electric Fields Unchanged
 - Magnetic Fields increased but within ICNIRP Guidelines
- Sustainability and the Environment
 - Utilising existing Assets
 - Optimising power flow along existing corridors
 - Minimal Land Damage
- Land Access
 - No new Towers
 - Minimal Landowner Interaction
 - No Planning Permission



Benefits 4/4

- Reduced Outage Duration
 - Stringing Time
 - Occasional Tower Refurbishment
 - Estimated 50% reduction in duration.



Case Study 1 – Killonan - Knockraha

- 220kV Line constructed in 1960s
- 430mm² Bison Operated @ 60°C
- Fully Refurbished in 2006

- Uprate to 430mm² @ 80°C required for 2010 (associated with Cork CCGTs)

- 3 Uprate Options Considered
 - 1: ACSR
 - 2: AAAC
 - 3: GAP (HTLS)





Case Study

Summary	430mm ² 80°C ACSR @	AAAC Equivalent	GAP Equivalent
No of spans violated (ground clearance)	92	32	0
No of violations below 0.4m	13	14	0
% of ground clearance violations along the line	38%	13%	0%
No. of structures to be replaced or modified	79	18 + 37 IMPs	0
Summer rating (A)	943	1005	1409



Case Study 2 – Cork Loop-ins

- Coolroe – Kilbarry, Coolroe – Inniscarra, Inniscarra - Macrooom
- 11 recently build towers
- 25% of Towers in 8km Section
- Cost Saving >€1m



Case Study 3 – Limerick - Moneteen

- 7km total length
- 2km double circuit section
- Construction / Planning Issues
- Cost Saving ~ €0.8m



Current Status & Next Steps

- Killonan – Knockraha
 - Contract award: 2009
 - Construction: July – October 2010
- Term Contract Conductor
 - Contract award: Q1 2010
- 2011 Projects
 - Cullenagh – Knockraha 220kV
 - Coolroe – Inniscara 110kV
 - Dunmanway – Macroom 110kV
 - Corduff – Ryebrook 110kV
 - Limerick – Moneteen 110kV



Thank you

Questions?

